

MINUTES

UTAH UNIFORM BUILDING CODE COMMISSION PLUMBING CODE/HEALTH ADVISORY COMMITTEE MEETING

March 8, 2012

**Ste 400 – 9:00 am
Spectrum Engineers
324 S State Street
Salt Lake City UT**

CONVENED : 9 :00

ADJOURNED 11:00

**Bureau Manager :
Board Secretary:**

Dan S. Jones
Sharon Smalley

Board Members Present:

Ray Moore
Mark Jenkins
Jody Hilton
Michael Moss
Jeffrey Park
Kevin Bell
Nathan Lunstad

Board Members Absent:

Kerry Cramer
William Green (excused)

Guests:

DOPL Staff Present:

TOPICS FOR DISCUSSION **MINUTES**

DECISIONS AND RECOMMENDATIONS

A motion was made by Jody Hilton to approve the minutes from the February 2, 2012 meeting as written. The motion was seconded by Nathan Lunstad and passed unanimously.

Ray Moore requested that the amendment previously approved for Section 312.5 number 5 be reviewed again. He pointed out that the wording for the requirement of “6 psi” needed to be changed. Following a discussion on the new amendment, a motion was made by Nathan Lunstad to change the

wording for number 5 to read “No water supply system shall be pressurized to a minimum of 50 psi but not more than 80 psi as measured by accurate gauges graduated to no more than three times the test pressure.” The motion was seconded by Kevin Bell and passed unanimously.

REVIEW PROPOSED
AMENDMENT FOR STATE
CONSTRUCTION CODE
ADOPTION ACT AND STATE
CONSTRUCTION CODE 15A-3-
303(1) TABLE 303.4

Michael Moss passed out a proposal for this current amendment. Following a review of the proposal by the committee, a motion was made by Michael Moss and seconded by Mark Jenkins to delete the current amendment and add a new amendment that would add an exception to Section 303.4. The motion passed unanimously.

15A-3-303(4) BACKFLOW
ASSEMBLY TESTING

The committee reviewed the current amendment for Section 312.10 through 312.10.2. Following a review of the current amendment, a motion was made by Mark Jenkins to delete the current amendment and add a new amendment that would add a new exception to Section 312.10.2. The motion was seconded by Kevin Bell. During the discussion on the motion, the proposal was modified by changing the word “exception” to “312.10.3” and adding a title as “Tester Qualifications”. The first and the second concurred with the modifications and the modified motion passed unanimously.

15a-3-303(2) AUTOMATIC
CLOTHES WASHER SAFE PAN

Ray Moore reported that no further modifications need to be made to the current amendment other than changing the reference number from 406.4 to 406.3. Following a discussion, a motion was made by Kevin Bell to keep the current amendment with the modification to the number. The motion was seconded by Jeff Park and passed unanimously.

Ray Moore will review the current amendment for Section 504.7.2 and he will give his report on this current amendment during the review of Chapter 10.

REVIEW OF CHAPTER 6 OF
2012 IPC

Following the review of the current amendment in 15A-3-306(1) and (2) for Section 602.3 through 602.3.5.1, a motion was made by Nathan Lunstad to keep both current amendments. The motion was seconded by Michael Moss and passed unanimously.

A motion was made by Jeff Park and seconded by Kevin Bell to keep the current amendment for 15A-3-306 (3) for Section 604.4.1. The motion passed unanimously.

The current amendments for 15A-3-306 (4) and (5) for Sections 606.5 and 606.5.11 were reviewed. Following the discussion on the current amendments, a motion was made by Ray Moore to keep the current amendment for Section 606.5 and to modify the current amendment for Section 606.5.11 by changing the words “20 psi” to “the minimum water pressure specified in Utah Administrative Code R309-105-9”. The motion was seconded by Kevin Bell and passed unanimously.

At this point Mark Jenkins & Dan Jones left the meeting.

Section 606.7 of the 2012 code was reviewed and Ray Moore will come back to the next meeting with any possible modification.

During the review of the current amendments for 15A-3-306 (6) and (7) Table 608.1 and Table 608.1.1, Michael Moss introduced a new proposal for this section. Following the discussion, a motion was made by Michael Moss to delete the current amendments (6) and (7) for Sections 608.1 and 608.1.1 and replace them with a new amendment for Table 608.1. The motion was seconded by Jody Hilton and passed unanimously.

The next meeting will be April 5th and will be held at Spectrum Engineers.

The meeting adjourned at 11:00.

Note: These minutes are not intended to be a verbatim transcript but are intended to record the significant features of the business conducted in this meeting. Discussed items are not necessarily shown in the chronological order they occurred.

April 5, 2012
Date Approved

s/s Ray Moore
Ray Moore
Chairperson, Uniform Building Code Commission
Plumbing/Health Advisory Committee

April 5, 2012
Date Approved

s/s Dan S. Jones
Dan S. Jones, Bureau Manager
Division of Occupational & Professional Licensing